# 2009 Annual Drinking Water Quality Report

(Consumer Confidence Report)

## CITY OF SLATON

Phone Number: (806) 828-2000

## SPECIAL NOTICE

Required language for ALL community public water supplies:

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly or immunocompromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline at (800) 426-4791.

# Public Participation Opportunities

Date: July 12th, 2010

Time: 6:30 P.M.

Location: Slaton City Hall

Phone Number: (806) 828-2000

To learn about future public meetings (concerning your drinking water), or to request to schedule one, please call us.

# Our Drinking Water Meets or Exceeds All Federal (EPA) Drinking Water Requirements

This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

WATER SOURCES: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water before treatment include: microbes, inorganic contaminants, pesticides, herbicides, radioactive contaminants, and organic chemical contaminants.

#### En Español

Este informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre éste informe en español, favor de llamar al tel. (806) 828- 2000 - para hablar con una persona bilingüe en español.

## Where do we get our drinking water?

Our drinking water is obtained from SURFACE water sources. It comes from the following Lake/River/Reservoir/Aquifer: LK MEREDITH CR. A Source Water Susceptibility Assessment for your drinking water sources(s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus our source water protection strategies. Some of this source water assessment information will be available later this year on Texas Drinking Water Watch at http://dww.tceq.state.tx.us/DWW/. For more information on source water assessments and protection efforts at our system, please contact us.

# ALL drinking water may contain contaminants.

When drinking water meets federal standards there may not be any health based benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

# **Secondary Constituents**

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondaries are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

# **About The Following Pages**

The pages that follow list all of the federally regulated or monitored contaminants which have been found in your drinking water. The U.S. EPA requires water systems to test for up to 97 contaminants.

#### **DEFINITIONS**

#### Maximum Contaminant Level (MCL)

The highest permissible level of a contaminant in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

### Maximum Contaminant Level Goal (MCLG)

The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

## Maximum Residual Disinfectant Level (MRDL)

The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

# Maximum Residual Disinfectant Level Goal (MRDLG)

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

#### Treatment Technique (TT)

A required process intended to reduce the level of a contaminant in drinking water.

#### Action Level (AL)

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

#### **ABBREVIATIONS**

- NTU Nephelometric Turbidity Units
- MFL million fibers per liter (a measure of asbestos)

- **ppb** parts per billion, or micrograms per liter  $(\mu g/L)$
- ppt parts per trillion, or nanograms per liter
- ppq parts per quadrillion, or picograms per liter

Inorganic Contaminants

Year Ran		Contaminant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Unit of Measure	Source of Contaminant
2005			4 nic value was ou will be not		4 nuary 23, 200	10 06. In the	0 event of	ppb a	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
2005		Barium	0.101	0.101	0.101	2	2	ppm	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
2005		. Chromium	6.7	6.7	6.7	100	100	ppb	Discharge from steel and pulp mills; erosion of natural deposits.
2009		Cyanide	50	30	70	200	200	ppb	Discharge from steel/metal factories; discharge from plastic and fertilizer factories.
2009	2008	Fluoride	1.05	0.63	1.46	4	4	ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
2009		Nitrate	1.05	1	1.1	10	10	ppm	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
2005		Combined Radium 226 & 228	0.7	0.7	0.7	5	. 0	pCi/L	Erosion of natural deposits.
2005		Gross beta emitters	6.5	6.5	6.5	50	0	pCi/L	Decay of natural and man-made deposits.
2005		Gross alpha	5	5	5	15	0	pCi/L	Erosion of natural deposits.

#### Organic Contaminants TESTING WAIVED, NOT REPORTED, OR NONE DETECTED

#### Maximum Residual Disinfectant Level

Year	Disinfectant	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Source of Disinfectant
2009	Chlorine Residual, Free	1.43	0.08	2.2	4	4	ppm	Disinfectant used to control microbes.
2009	Chloramine Residual	1.4	0.02	2.2	4	4	ppm	Disinfectant used to control microbes.

)isi n	fection	Byproducts	

Distillect	ion byproducts				-		
Year	Contaminant .	Average Level	Minimum Level	Maximum Level	MCL	Unit of Measure	Source of Contaminant
2008	Total Haloacetic Acids	18.5	18.5	18.5	60	ppb	Byproduct of drinking water disinfection.
2008	Total Trihalomethanes	29.6	29.6	29.6	80	ppb	Byproduct of drinking water disinfection.

Unregulated Initial Distribution System Evaluation for Disinfection Byproducts WAIVED OR NOT YET SAMPLED

#### **Unregulated Contaminants**

Bromoform, chloroform, dichlorobromomethane, and dibromochloromethane are disinfection byproducts. There is no maximum contaminant level for these chemicals at the entry point to distribution.

Year or Range	Contaminant	Average Level	Minimum Level	Maximum Level	Unit of Measure	Source of Contaminant
2009	Chloroform	4.8	4.8	4.8	ppb	Byproduct of drinking water disinfection.
2009	Bromoform	3.5	3.5	3.5	ppb	Byproduct of drinking water disinfection.
2009	Bromodichloromethane	9.5	9.5	9.5	ppb	Byproduct of drinking water disinfection.
2009	Dibromochloromethane	14	14	14	ppb	Byproduct of drinking water disinfection.

Lead and Copper

Year	Contaminant	The 90th Percentile	Number of Sites Exceeding Action Level	Action Level	Unit of Measure	Source of Contaminant
2007	Lead	1	0	15	ppb	Corrosion of household plumbing systems; erosion of natural deposits.
2007	Copper	0.03	0	1.3	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

#### Required Additional Health Information for Lead

"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead,"

#### Turbidity

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

Year	Contaminant	Highest Single Measurement	Lowest Monthly % of Samples Meeting Limits	Turbidity Limits	Unit of Measure	Source of Contaminant
2009	Turbidity	0.10	100.00	0.3	NTU	Soil runoff.

Page 4 of 5

Total Coliform REPORTED MONTHLY TESTS FOUND NO COLIFORM BACTERIA.

Fecal Coliform REPORTED MONTHLY TESTS FOUND NO FECAL COLIFORM BACTERIA.

2009 Annual Drinking Water Quality Report

# Secondary and Other Constituents Not Regulated (No associated adverse health effects)

Year or Range		Constituent	Average Level	Minimum Level	Maximum Level	Secondary Limit	Unit of Measure	Source of Constituent	
2009	2008	Bicarbonate	225	220	229	NA	ppm	Corrosion of carbonate rocks such as limestone.	
2005		Calcium	62.4	62.4	62.4	NA	ppm	Abundant naturally occurring element.	
2009	2003	Chloride ·	139	12	266	300	ppm	Abundant naturally occurring element; used in water purification; byproduct of oil field activity	
2005		Copper	0.016	0.016	0.016	1	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.	
2008		Hardness as Ca/Mg	239	218	259	NA	ppm	Naturally occurring calcium and magnesium.	
2005		Magnesium	14.1	14.1	14.1	NA	ppm	Abundant naturally occurring element.	
2005		Nickel	0.002	0.002	0.002	NA	ppm	Erosion of natural deposits.	
2009	2008	pН	7.6	7.6	7.7	>7.0	units	Measure of corrosivity of water.	
2009	2005	Sodium	133	33	233	NA	ppm	Erosion of natural deposits; byproduct of oil field activity.	
2009	2008	Sulfate	105	34	176	300	ppm	Naturally occurring; common industrial byproduct; byproduct of oil field activity.	
2009	2008	Total Alkalinity as CaCO3	205	180	229	NA	ppm	Naturally occurring soluble mineral salts.	
2009	2008	Total Dissolved Solids	606	363	848	1000	урт	Total dissolved mineral constituents in water.	
2005		Zinc	0.004	0.004	0.004	. 5	ppm	Moderately abundant naturally occurring element used in the metal industry.	